



APPROVED CONTRACTOR



Oaktree Electrical

Part P No: 27236935

This certificate is not valid if the serial number has been defaced or altered

216158

DCR18

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR

Registration No: 026200000
Trading Title: Oaktree Electrical Ltd
Address: Unit 4 Court Lodge Centre, Plaxdale Green Road, Stansted, Kent
Postcode: TN15 7PG Tel No: 01322 552888

DETAILS OF THE CLIENT

Contractor Reference Number (CRN):
Name: Bugler Developments Ltd
Address: Bugler House , 25 High Street, Rickmansworth
Postcode: WD3 1ET Tel No:

DETAILS OF THE INSTALLATION

Occupier:
Address: Flat 3, 35 Wellington Road, London
Postcode: E6 2EE Tel No:

PART 2 : DETAILS OF THE ELECTRICAL WORK COVERED BY THIS INSTALLATION CERTIFICATE

Date works completed: 03/08/2021

The installation is -

New:

An addition:

An alteration:

Replacement of a consumer unit:

Description and extent of the installation covered by this certificate:

All fixed 230V wiring

Where necessary, continue on a separate numbered page: Page No(s) (N/A)

PART 3 : NEXT INSPECTION OF THE ELECTRICAL INSTALLATION

I RECOMMEND that this installation is further inspected and tested after an interval of not more than: 10 years

PART 4 : DECLARATION FOR THE ELECTRICAL INSTALLATION WORK

DESIGN, CONSTRUCTION, INSPECTION & TESTING

I, being the person responsible for the design, construction, inspection and testing of the electrical installation, particulars of which are described in PART 2, having exercised reasonable skill and care when carrying out the design and additionally where this certificate applies to an addition or alteration, having confirmed that the safety of the existing installation is not impaired, hereby CERTIFY that the design, construction, inspection and testing for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671: 2018, amended to (date) except for the following departures, if any, identified: details on attached page(s) (N/A) (Regulations 120.3, 133.1.3 and 133.5). Where selectivity is required, details of the verification appended (536.4): Page No(s) ()

Name (capitals): MR SHANE BOBBETT

Signature:

Date: 03/08/2021

REVIEWED BY QUALIFIED SUPERVISOR

Name (capitals): MR TONY USHER

Signature:

Date: 06/08/2021

*The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.

Original to the person ordering the work

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 5 : COMMENTS ON THE EXISTING INSTALLATION *(in the case of an addition or alteration see regulation 644.1.2)*

(see additional page No. N/A)

PART 6 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type and earthing arrangements

TN-C-S: TN-S: TT:

Other (state):

Supply protective device

(BS (EN) 1361)

Type: (I**lb**)

Rated current: (100) A

Number and type of live conductors

AC 1-phase, 2-wire:

Other (state):

Confirmation of supply polarity: ()

Other sources of supply: *(as detailed on attached schedule)* Page No: ()

Nature of supply parameters

Nominal line voltage to Earth, U_0 : (230) V ⁽¹⁾ *By enquiry, measurement, or by calculation*
 Nominal frequency, f : (50) Hz
 Prospective fault current, $I_{pf}^{(1)*}$: (0.927) kA
 External loop impedance, $Z_e^{(1)*}$: (0.25) Ω

PART 7 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS CERTIFICATE

Maximum demand (load): () A

Means of Earthing

Distributor's facility: ()

Installation earth electrode: ()

Where an earth electrode is used insert

Type - rod(s), tape, etc: ()

Location: ()

Electrode resistance to Earth: () Ω

Main protective conductors

Earthing conductor:

(material Copper csa 16 mm²)

Connection / continuity verified:

Main protective bonding conductors:

(material Copper csa 10 mm²)

Connection / continuity verified:

Main protective bonding connections

Water installation pipes: ()

Gas installation pipes: ()

Structural steel: ()

Oil installation pipes: ()

Lightning protection: ()

Other (state) :

Main switch / Switch-fuse / Circuit-breaker / RCD

Type: (BS (EN) 60947-3)

Location: (Utility Cupboard)

No. of poles: (2) Rating / setting of device: (n/a) A

Current rating: (100) A Voltage rating: (230) V

Where an RCD is used as the main switch

RCD rated residual operating current, $I_{\Delta n}$: (n/a) mA

Measured operating time: (n/a) ms Rated time delay: (n/a) ms

PART 8 : SCHEDULES AND ADDITIONAL PAGES

Schedule of Inspections

Page No(s): (3 & 4)

Schedule of Circuit Details and Test Results for the installation

Page No(s): (5)

Additional pages, including data sheets for additional sources

Page No(s): ()

Special installations or locations *(indicated in item 11.1 on page 4)*

Page No(s): ()

Continuation sheets

Page No(s): (N/A)

The pages identified are an essential part of this certificate.

**Where the installation is supplied by more than one source, the higher or highest values of prospective fault current, I_{pf} , and external earth fault loop impedance, Z_e , must be recorded.*

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED

<p>1. External condition of intake equipment (visual inspection only) (If inadequacies are identified with the intake equipment, it is recommended the person ordering the report informs the appropriate authority.)</p> <p>1.1 Service cable: (✓)</p> <p>1.2 Service head: (✓)</p> <p>1.3 Earthing arrangement: (✓)</p> <p>1.4 Meter tails:</p> <p>a) Cutout fuse to meter (✓)</p> <p>b) Meter to consumer unit (✓)</p> <p>1.5 Metering equipment: (✓)</p> <p>1.6 Isolator (where present): (✓)</p>	<p>5. Additional protection</p> <p>5.1 Presence and effectiveness of additional protection methods:</p> <p>a) RCD(s) not exceeding 30 mA operating current (✓)</p> <p>b) Supplementary bonding (N/A)</p> <p>6. Other methods of protection</p> <p>6.1 Presence and effectiveness of methods which give both basic and fault protection:</p> <p>a) SELV system including the source and associated circuits (N/A)</p> <p>b) PELV system including the source and associated circuits (N/A)</p> <p>c) Double or reinforced insulation i.e. Class II or equivalent equipment and associated circuits (✓)</p> <p>d) Electrical separation for one item of equipment e.g. shaver supply unit (✓)</p>	<p>7.13 Presence of appropriate circuit charts, warning and other notices:</p> <p>a) Provision of circuit charts/schedules or equivalent forms of information (✓)</p> <p>b) Warning notice of method of isolation where live parts not capable of being isolated by a single device (✓)</p> <p>c) Periodic inspection and testing notice (✓)</p> <p>d) Presence of RCD six-monthly notice, where required (✓)</p> <p>e) Warning notice of non-standard (mixed) colours of conductors present (N/A)</p> <p>7.14 Presence of labels to indicate the purpose of switchgear and protective devices: (✓)</p>
<p>2. Presence of adequate arrangements for other sources</p> <p>2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply: (N/A)</p> <p>2.2 Adequate arrangements where generating set operates in parallel with the public supply: (N/A)</p> <p>2.3 Presence of alternative / additional supply warning notices: (N/A)</p>	<p>7. Consumer unit(s) / distribution board(s)</p> <p>7.1 Adequacy of access and working space for items of electrical equipment including switchgear: (✓)</p> <p>7.2 Components are suitable according to assembly manufacturer's instructions or literature: (✓)</p> <p>7.3 Presence of linked main switch(es): (✓)</p> <p>7.4 Isolators, for every circuit or group of circuits and all items of equipment: (✓)</p> <p>7.5 Suitability of enclosure(s) for IP and fire ratings: (✓)</p> <p>7.6 Protection against mechanical damage where cables enter equipment: (✓)</p> <p>7.7 Confirmation that ALL conductor connections are correctly located in terminals and are tight and secure: (✓)</p> <p>7.8 Avoidance of heating effects where cables enter ferromagnetic enclosures e.g. steel: (✓)</p> <p>7.9 Selection of correct type and ratings of circuit protective devices for overcurrent and fault protection: (✓)</p> <p>7.10 Confirmation overvoltage protection (SPDs) provided where specified: (N/A)</p> <p>7.11 Indication of SPDs continued functionality confirmed: (N/A)</p> <p>7.12 Adequacy of AFDD(s), where specified: (N/A)</p>	<p>8. Circuits</p> <p>8.1 Adequacy of conductors for current-carrying capacity with regard to type and nature of the installation: (✓)</p> <p>8.2 Cable installation methods suitable for the location(s) and external influences: (✓)</p> <p>8.3 Segregation/separation of Band I (ELV) and Band II (LV) circuits, and electrical and non-electrical services: (✓)</p> <p>8.4 Cables correctly erected and supported throughout, with protection against abrasion: (✓)</p> <p>8.5 Provision of fire barriers, and sealing arrangements where necessary: (✓)</p> <p>8.6 Non-sheathed cables enclosed throughout in conduit, ducting or trunking: (✓)</p> <p>8.7 Conductors correctly identified by colour, lettering or numbering: (✓)</p> <p>8.8 Presence, adequacy and correct termination of protective conductors: (✓)</p> <p>8.9 Cables and conductors correctly connected, enclosed and with no undue mechanical strain: (✓)</p> <p>8.10 No basic insulation of a conductor visible outside enclosure: (✓)</p> <p>8.11 Single-pole devices for switching or protection in line conductors only: (✓)</p> <p>8.12 Accessories not damaged, securely fixed, correctly connected, suitable for external influences: (✓)</p> <p>8.13 Cables concealed under floors, above ceilings or in walls / partitions, adequately protected against damage: (✓)</p>
<p>3. Automatic disconnection of supply</p> <p>3.1 Presence and adequacy of earthing and protective bonding arrangements:</p> <p>a) Installation earth electrode (where applicable) (✓)</p> <p>b) Earthing conductor and connections, including accessibility (✓)</p> <p>c) Main protective bonding conductors and connections, including accessibility (✓)</p> <p>d) Provision of safety electrical earthing/bonding labels at all appropriate locations (✓)</p> <p>e) RCD(s) provided for fault protection (✓)</p> <p>4. Basic protection</p> <p>4.1 Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:</p> <p>a) Insulation of live parts e.g. conductors completely covered with durable insulating material (✓)</p> <p>b) Barriers or enclosures e.g. correct IP rating (✓)</p>		

Original to the person ordering the work



This certificate is not valid if the serial number has been defaced or altered

216158

DCR18

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Small installations up to 100 A single phase supply

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 10 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing:

CODES For Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state																		
Circuit number	Circuit description <small>*Where this consumer unit is remote from the origin of the installation, record details of the circuit supplying this consumer unit on the first line.</small>	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device** (Ω)	Circuit impedances (Ω)			Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons					
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)				Live / Earth (MΩ)	Test voltage DC (V)	RCD	AFDD		
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ +R ₂)	R ₂										
1	Hob	A	C	2	6.0	2.5	0.4	60898	B	32	6	30	1.08				0.19			>299	>299	500	✓	0.64	34.8	✓		
2	Sockets	A	C	11	2.5	1.5	0.4	60898	B	32	6	30	1.08	1.25	1.25	0.84				>299	>299	500	✓	0.77	34.8	✓		
3	Heat Meter	A	C	1	2.5	1.5	0.4	60898	B	16	6	30	2.18					0.09	>299	>299	500	✓	0.68	34.8	✓			
4	Cupboard Sockets	A	C	2	2.5	1.5	0.4	60898	B	16	6	30	2.18					0.05	>299	>299	500	✓	0.4	34.8	✓			
5	Lights	A	C	15	1.5	1.0	0.4	60898	B	6	6	30	5.82				0.75	>299	>299	500	✓	0.95	34.8	✓				
6	Smokes	A	C	5	1.5	1.0	0.4	60898	B	6	6	30	5.82				0.72	>299	>299	500	✓	0.84	34.8	✓				
7	Spare																											
8	RCD																											
9	RCD																											
10	Kitchen Sockets	A	C	8	2.5	1.5	0.4	60898	B	32	6	30	1.08	0.52	0.52	0.62				>299	>299	500	✓	0.53	16.6	✓		
11	Oven	A	C	2	2.5	1.5	0.4	60898	B	16	6	30	2.18				0.17	>299	>299	500	✓	0.43	16.6	✓				
12	Leak Meter	A	C	1	2.5	1.5	0.4	60898	B	16	6	30	2.18						>299	>299	500	✓	0.61	16.6	✓			
13	Alarm	A	C	1	2.5	1.5	0.4	60898	B	6	6	30	5.82						>299	>299	500	✓	0.64	16.6	✓			
14	Bath Lights/MEV	A	C	6	1.5	1.0	0.4	60898	B	6	6	30	5.82				0.27	>299	>299	500	✓	0.65	16.6	✓				
15	Spare																											
16	Spare																											
17	Spare																											

Location of consumer unit: Utility Cupboard Designation: DB001 Prospective fault current at consumer unit (where applicable): (0.927) kA

TESTED BY
 Name (capitals): MR SHANE BOBBETT Position: Electrician Signature: [Signature] Date: 03/08/2021

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: <u>1008121101667171</u>	Continuity:	Insulation resistance:	Earth fault loop impedance:	Earth electrode resistance:	RCD:
--	----------------------	---------------------------------	--------------------------------------	--------------------------------------	---------------

Original to the person ordering the work